

Water System Name: Cougar Creek Water Users		PWS ID No.: 1090030 RE
Collector: Dion Holton	Date Collected: 04/07/2026	County: Bonner
Report Results to: Cougar Creek Water Users Alan Ameche P.O. Box 231 Coolin, ID 83821		
Phone: (208) 610-2389	Fax:	
E-Mail: alanameche@hotmail.com,pwsreports@deq.idaho.gov,dholton@idahoruralwater.com		

COLIFORM BACTERIA

ANALYSIS REPORT

CONTAMINANT ID# 3100

Type of System:	Public
Type of Sample:	Compliance Sample
Lab Order No.:	2026040133

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks.

Laboratory Name: Accurate Testing Labs, LLC 7950 Meadowlark Way Coeur d'Alene, ID 83815 Phone (208) 762 8378 Fax (208) 762 9082 Web site: www.accuratetesting.com E-mail: info@accuratetesting.com Lab EPA ID No: ID00912
--

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

Sample Number	Sample Type	Sample Location	Time Collected	Chlorine Residual ppm	Original Sample Date	Total Coliform Method: SM9223B-PA	E. Coli Method: SM9223B-PA
296211	RS-Routine Sample	25 Erhart Lane	07:00			Absent	Absent

Sample Transportation by (Name):	Dion Holton	Date/Time:	04/07/2026 11:55	Analyst: LN	Date Analyzed: 04/08/2026
Sample Received by (Name):	JM	Date/Time:	04/07/2026 11:55	Supervisor: Rhena Cooper	
Remarks:				Date Reviewed and Printed: 04/09/26	