

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www.accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2026010361**

Page: 1 of 2

Cougar Creek Water Users
P.O. Box 231
Coolin , ID 83821

Project: PFAS Report PWS#1090030

Date Received: 01/19/2026 13:45

Sample: **2**
Location: Well # 2
Sample Type: Raw Water

Matrix: Drinking Water
D/T Collected: 01/19/2026 09:00
Collected by: Dion Holton

Analyte	Result	Unit	Method	PQL	Analysis Date	Analyst
11CI-PF3OUdS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFBS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFDA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFDaA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFEESA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFHpA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFHpS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFHxA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFHxS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFMBA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFMPA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
4:2FTS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFNA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFOA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFOS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFPeA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFPeS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
PFUnA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
6:2FTS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
8:2FTS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
9CI-PF3ONS	ND	ng/L	EPA 533	2.00	01/30/26	ANA
ADONA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
HFPO-DA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
NFDHA	ND	ng/L	EPA 533	2.00	01/30/26	ANA

Comments:

[Sub Lab: Anatek](#)



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 02/09/26

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2026010361**

Page: 2 of 2

PFBA	ND	ng/L	EPA 533	2.00	01/30/26	ANA
Temperature (Sample Received)	2.7	deg. C	Infrared		01/19/26	JM

If the RESULT is 'ND' (Not Detected) or 'Absent', that means the concentration is less than the PQL (Practical Quantitation Limit for this method).

Comments:

Sub Lab: Anatek



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 02/09/26